

# Policy and Planning to Address Impacts of Forest Fires to Source Water Quality



Troy Hayes, P.E.  
City of Phoenix  
Water Services  
Deputy Director  
(Water Quality)

October 28, 2011

# Story Table of Contents

---

- Background
- The Plan
- The Plan Update
- The Event
- Question the Plan
- The New Plan
- The New Old Plan
- Steps for the Future





# City of Phoenix Background

- Six Surface Water Treatment Plants
  - Two water sources
  - 100 Billion Gallons per year
- 540 Square Miles of Service Area
  - 400,000 Accounts
  - 7,000 miles of distribution mains
- System Conditions
  - Periods of elevated TOC Levels
  - Higher Temperature
  - 77 Major Pressure Zones
    - Water Age (5+ days)
    - Chlorine Residual





**Colorado River (CAP)**

**43%**



**Groundwater**


**3%**

**Verde River**




**49%**

**Combined**




**Reclaimed Wastewater**

**Salt River**





# Historical Total Organic Carbon in Source Waters (up to 2001)



# Chapter 1 - The Plan (1989)

## Water Quality Master Plan *EXECUTIVE SUMMARY*

Water and Wastewater Department  
City of Phoenix, Arizona

*September 1989*





**MALCOLM  
PIRNIE**

In association with John Carollo Engineers



City of Phoenix

# First Water Quality Master Planning Effort



SDWA

SDWA

THM  
Rule





# Purpose of 1989 Water Quality Master Plan

---

- Identify water quality improvement options for City's potable water delivery
  - Consider changing/uncertain regulatory environment
  - Provide healthful and best quality water to customers
  - Robust multiple barriers for multitude of contaminants
- Recommend long-term strategies for treatment process upgrades
- Identify key decision points






# Highlights of 1989 Water Quality Master Planning Approach

---

- Seek advice of leading water industry experts to gauge regulatory direction and best approach for compliance
- Conduct extensive bench and pilot-scale evaluation of potential treatment strategies
- Analyze treatment options for feasibility and cost
- Develop a road map with identified decision points
- Recommend short-term and long-term CIP strategies



# Roadmap from 1989 Plan





# 1989 WQMP Recommendations

---

- Maintain chlorine usage
  - Primary and Secondary
- Reduce dissolved organics within existing design
  - Enhanced Coagulation
- Optimize distribution system to reduce water age



# 1989 WQMP Recommendations cont.

---

“At such time removal of TOC is required beyond capability of the plants, as designed, a choice will need to be made.”


Options to be evaluated in future

- Enhanced TOC removal through GAC
- Change from free chlorine to chloramines






# Chapter 2 - The Plan Update (2006)





# New Regulatory Drivers for Water Quality Planning





# Stage 2 DBP Rule

---

- Aimed at reducing customer exposures to harmful disinfection by products (Trihalomethanes and Haloacetic Acids)
  - DBPs have been regulated since 1979
  - New Rule does not allow averaging over the entire system
  - Compliance is required beginning 2<sup>nd</sup> Q 2012
- City of Phoenix challenges for compliance with this rule include:
  - Elevated water temperatures
  - Long water age



# Purpose of 2006 Water Quality Master Plan Update

---

- Re-assess water quality goals and underlying philosophy of potable water treatment
  - Consider water quality parity
  - Consider improvements in treatment technology
  - Incorporate new information about disinfection, DBPs, and other contaminants
- Recommend treatment process upgrades needed for the known and emerging regulations






# Highlights of 2006 Water Quality Master Planning Approach

---

- Stakeholder input from various City divisions to develop a consensus about potential strategies
- Examine chloramination
- Perform scenario planning to address future uncertainties
- Conduct extensive pilot-scale
  - GAC
  - Chloramination, and Ozonation



# Historic TOC Values




CAP water data compiled from Union Hills WTP and Pyramid Peak WTP (Glendale) raw water data

SRP water data compiled from 24th Street WTP and Cholla WTP (Glendale) raw water data



# Results of Alternatives Evaluation



# Recommendations from 2006 Water Quality Master Plan


---

- Implement GAC Filter Adsorbers at all WTPs based on:
  - Additional cost of GAC is still within the comfort zone in light of the fact that the risks of exposure to contaminants is greatly minimized with GAC treatment
- Chlorine dioxide is recommended
  - Preoxidant to precipitate iron and manganese
  - Allows for the elimination of prechlorination






# Chapter 3 - The Event



June 2002 Rodeo Chediski Fire

# Rodeo-Chediski Fire


468,638 acres  
June 2002




Standing dead trees on the Rodeo-Chediski Fire area.



# Fire Impact on Watershed



# Changes in Source Water Quality



CAP water data compiled from Union Hills WTP and Pyramid Peak WTP (Glendale) raw water data

SRP water data compiled from 24th Street WTP and Cholla WTP (Glendale) raw water data



# Chapter 4 -Question the Plan (Take a Trip)

GAC

UV

KMnO<sub>4</sub>

Enhanced  
Coagulation

Membrane



City of Phoenix



Ozone

MIEX



# Initiation of GAC Roadmap





# Primary Reasons for Concerns about the recommended approach

---

- Prolonged period of elevated TOC would require frequent replacement of GAC resulting in:
  - Operational hardship
  - Financial hardship



# What Changed?

---

- Re-evaluation of Water Quality Philosophy
  - DBP Rule Compliance (Primary Focus) While Maintaining Flexibility to Implement Long-Term Water Quality Goals
  - Allow 90% TTHM MCL
  - Allow for WTP Specific TOC Targets
  - Allow for Seasonal TOC Targets
    - 1<sup>st</sup> and 4<sup>th</sup> Quarter - 56 ug/L TTHM
    - 2<sup>nd</sup> and 3<sup>rd</sup> Quarter – 88 ug/L TTHM
- Reduce life cycle costs of GAC Program





# GAC Road Map Project Considered Alternatives (Lower Life cycle costs)

GAC

UV

KMnO<sub>4</sub>

Enhanced  
Coagulation

Membrane



City of Phoenix




Ozone

MIEX



# 7-Yr Cycle GAC O&M Costs plus ClO2 + FeCl2 O&M Costs





# GAC Road Map Results

---

- Continue with GAC Program

- GAC Filter Adsorbers

- VV WTP and DV WTP

- Filter Contactors

- 24<sup>th</sup> Street WTP

- Biologically Active GAC Filters

- UH WTP


- Chlorine Dioxide

- Pre-Oxidant at 1 ppm max

- Optimize Enhanced Coagulation




# Chapter 5 - The New Plan – High Rate Chlorine Dioxide





# Revised Water Quality Strategy



# Key Factors Considered


---

- Operational Flexibility
  - Multiple tools
  - Technologies can be switched “on/off”
  - Opportunities for operational cost savings
- Maximize Future Options
  - Adaptability to future regulatory changes
- Life Cycle Cost
  - Total costs of the compliance strategy





# Chlorine Dioxide RSSCTs – SDS DBP Testing



TOC target increases when  $\text{ClO}_2$  is applied:

- 1.60 mg/L for Baseline EC
- 2.40 mg/L for  $\text{ClO}_2$  pre-treatment



# Compliance Strategy

---

- Initial Strategy

- Granular Activated Carbon (GAC) Filters } Removes THM precursors

- Revised Strategy

- GAC Filters } Removes THM precursors
- High Rate Chlorine Dioxide } Reduces formation of THMs
- Distribution System Optimization } Reduces water age


*Various combinations of these tools resulted in 11 alternative operating scenarios that are evaluated in detail*





# Features of Selected Alternative

- Post-Filter Contactors at Val Vista
- Filter Adsorbers at Deer Valley
- 3 ppm Chlorine Dioxide at all WTPs
- Distribution system optimization



# Cost Comparison

## Original Program

- ***Capital Cost = \$243M***
- ***O&M Cost = \$31M/Yr to \$46M/Yr***

## Revised Strategy

- *Capital Cost = \$238M*
- *O&M Cost = \$25M/Yr to \$34M/Yr*





# Unintended Consequences- Customer Concerns

Startup

C1 ON

C1 OFF





- Rusty Water
- Milky/Dirty
- Bad Taste/Odor

# Unintended Consequences- Customer Concerns

C2 ON

C2 OFF

C3 ON



- Rusty Water
- Milky/Dirty
- Bad Taste/Odor



# Unintended Consequences- Customer Concerns

C3 OFF

C4 ON




**Non-Issue**

- Rusty Water
- Milky/Dirty
- Bad Taste/Odor

# Accounting for TOC and Temp, Salt River TTHM Formation Decreased by 16-35%


FS25





# No Reduction in TTHM formation was Observed for Verde River Water

FS25



# Chapter 6 - The New Old Plan (Oct. 2010)

---

- Stop Design and Construction of 3 mg/l Chlorine Dioxide
- Implement GAC at all WTPs and 1 mg/l Chlorine Dioxide
  - Val Vista WTP GAC Contactors
  - Deer Valley WTP GAC Filter Adsorbers
  - Union Hills and 24<sup>th</sup> Street WTPs Biological GAC Filters
    - Previously designed filter adsorber plans modified



## Distribution System Optimization

---



# An Optimized Plan

---

- Distribution System Aeration Treatment
- Reduced Water Age
  - Piping and Reservoir Reconfiguration
- Optimization of Reservoirs on WTPs Sites
  - pH Control thru CT Reservoirs
  - Chlorine Control thru CT Reservoirs



# Steps for the Future

- Continue to optimize system
  - Addition of system Aeration treatment
  - System piping modifications
- Regional GAC Regeneration
- System GAC Treatment
- Water Quality Monitoring





---

The Moral of the Story – Our plan included a robust treatment system that allowed for flexibility. We believe that we can handle future Water Quality challenges.



# Questions

